

ROCKINGHAM COUNTY DEPARTMENT OF PUBLIC HEALTH

Permit Number AW051514-2

Improvement Permit 5-15-19 Expiration Date—Transferable

Repair

Authorization for Wastewater System Construction (Expires five years from date of issuance of Improvement Permit)

Operation Permit IIa System Classification Type Authorization to Connect to Wastewater System

TAX PIN NUMBER: 796600553905

APPLICANT NAME: COMER

DEBORAH

K

PROPERTY INFORMATION

OWNER INFORMATION

Road Name: SETTLE BRIDGE RD 361
 Subd/Park:
 Section :
 Lot # :
 Lot Size : 14.7

COMER DEBORAH K
 361 SETTLE BRIDGE ROAD
 REIDSVILLE NC 27320
 336 427 3594

Water Supply : PRIVATE WELL

65, R SETTLE BRIDGE RD, 1/2 MI ON R

	IMP Name	DATE	LAYOUT	SPECIFICATIONS	INSTALLED
<input checked="" type="checkbox"/> House	<u>3</u> #bedrooms		<u>existing</u>	Septic Tank	
Singlewide	<u>4</u> #people			Pump Tank	
Doublewide	basement			Drainfield sq ft	
Commercial	basement w/		<u>1200</u>	Water Supply	
Food Service	plumbing		<u>pr.well</u>	#of lines	
Seats	addition		<u>4-5</u>	Total length of lines	
Other			<u>400'</u>	Trench depth	
<u>360</u> GPD Design Wastewater Flow			<u>35'-38"</u>	Trench width	
TYPE SYSTEM			<u>36"</u>	Depth of rock below pipe	
<input type="checkbox"/> New	<input checked="" type="checkbox"/> Repair	<input type="checkbox"/> Expansion	<u>6"</u>	Total rock depth	
<input checked="" type="checkbox"/> Conventional	<input type="checkbox"/> Existing	<input type="checkbox"/> Pump	<u>12"</u>	Distance to foundation	
L.P.P.			<u>75'</u>	Distance to property lines	
Saprolite.1956(6)			<u>210'</u>	Distance to well	
Innovative				Watershed	
Other					
	INSTALL ON CONTOUR				
	LANDSCAPE PROMPTLY				
	<u>Install bullman valve</u>				

AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION

OPERATION PERMIT

See attached diagram

FS-Reviewed

Signed: Angela Inghatt, REHS Date: 5-15-14

Signed: _____ Date: _____

APPEALS: By written petition to the Office of Administrative Hearings, 6714 Mail Service Ctr., Raleigh, North Carolina 27699-6714. In accordance with GS.150B-23(a). **THIS PERMIT** may be suspended or revoked upon a finding that a violation...or a condition imposed upon the permit has occurred...Also upon a finding that its issuance was based on incorrect or inadequate information...GS.130A-23(a)(c)(d). Septic Tanks require effluent filters, and access devices...GS.130A-335.1.



14.73A

ROCKINGHAM COUNTY ENVIRONMENTAL HEALTH

Disclaimer: Rockingham County shall not be liable for any errors in this data. This includes errors of omission, commission, errors concerning the content of the data, and relative and positional accuracy of the data. Primary sources of this data must be consulted for verification of data.

1 inch = 100 feet